



***" Room humidity and temperature
transducer
RH & T ► MODBUS RTU "***

1. Introduction

The subject of this study is the characteristics of the humidity transducer functionality and temperature based on the sensor company Sensirion SHT series, with RS - 485 with built-in MODBUS RTU protocol, with optional RH analog output with 0 - 10V

ATTENTION: Before starting the module, please read the text contained in this study.

1.1. Device functions

- **relative humidity** measurement
- optional analog voltage output 0-10 [V] (in the range of 0-100% RH)
- **temperature** measurement
- calculation of the dew point
- LED signaling device operation
- serial RS-485 interface (reading of measured values, configuration of work parameters)
 - MODBUS RTU protocol
 - communication in HALF DUPLEX mode
 - hardware configurable address (1-127)
 - hardware configurable speed (9600, 19200, 38400, 57600, 115200)

1.2. Characteristics of the device

The basic function of the HCRH-Modbus transducer is to determine instantaneous values of relative humidity compensated by temperature and parallel instantaneous temperature values. Measured by the Sensirion SHT integrated sensor, then recalculated and averaged in the microcontroller, they are available in its memory (in HOLDING REGISTERS) according to the MODBUS standard. The registers are read in using the MODBUS protocol functions transmitted over the RS-485 serial interface. Sensor / sensor error signaling is carried out via the status register. Optionally, the relative humidity value is also presented in analogue form voltage output with 0 - 10 [V].

2. Technical data

2.1. General parameters of the transducer

Power	
- constant voltage	DC 24V (20 ... 30V)
- alternating voltage	AC 24V (20 ... 27,6V)
Power consumption	
- typical ¹⁾	<13,0 mA
- maximum ²⁾	<23.0 mA
LED signaling	0.2 Hz
Installation connector	screw in 5.00mm pitch (≤ 2.5mm ²)
dimensions	80 x 80 x 25 (L x H x W)
Weight	65 g
Assembly ³⁾	wall
Working environment	dust-free, air, neutral gases
Working temperature	0 ° C ÷ 50 ° C

- 1) Average device current consumption in the following conditions: transmission of 10 queries per second; transmission speed 9600 b / s; simultaneous reading of 3 registers; bus terminating resistors 2 x 120 Ω; 24V DC power supply, voltage output with a 10k resistive load;
- 2) Maximum momentary current consumption of the device in conditions as in point 1) + voltage output with a 1k resistive load;
- 3) The device should be installed by qualified personnel; Vertical orientation according to the marking
UP - up, DOWN - down;

2.2. Humidity measurement parameters

Sensor type	SHT21D
Measurement range	0 ÷ 100% RH
Resolution	12 bits (0.04% RH)
Accuracy for T = 25 ° C	
- in the range of 20 ÷ 80% RH	± 2% RH
- in the remaining range	± (2 ÷ 3) % RH
Hysteresis	± 1% RH
Sampling frequency	1 Hz
Response time ¹⁾	8s

- 1) The condition for obtaining the given response times is air flow > 1m / s at 25 ° C; the response time given is equal to one time constant corresponding to 63% of the set value;

2.3. Parameters of temperature measurement

Sensor type	SHT21D
Resolution	14 bits (0, 01 ° C)
Measurement range	0 ° C ÷ 50 ° C
Accuracy	
- in the range of 10 ÷ 50 ° C	± 0, 3 ° C
- in the range of 0 ÷ 60 ° C	± 0, 4 ° C
- in the remaining range	± (0, 4 ÷ 1.0) ° C
Sampling frequency	1 Hz
Response time ¹⁾	5 ÷ 30 s

- 1) The condition for obtaining the given response times is air flow > 1m / s; the response time given is equal to one time constant corresponding to 63% of the set value;

2.4. Parameters of the analog output

Output type	voltage
Output range	10 volts
Resolution	12 bits (5 mV)
Load capacity	$R_L > 1 \text{ k}\Omega$
Refresh rate	1 Hz

2.5. Parameters of the serial interface

Physical layer	RS-485
Communication protocol	MODBUS RTU
Connection configurations ¹⁾	HALF DUPLEX
Transmission speeds	9600/19200/38400/57600/115200 b / s

1) HALF DUPLEX - two-way communication with one pair of wires;

3. Installation

3.1. Security

- The device should be installed by qualified personnel!
- All connections should be made in accordance with the wiring diagrams set out in this specification!
- Before commencing the commissioning, check all electrical connections!

3.2. The construction of the device




Figure 1. View of the circuit of the printed version of the **wall** transducer.

3.3. Description of leads




Figure 2. Transducer terminal description in a **wall** version .

H1-connection pins
S1-reset of interface setting
S2- setting of interface address
J1- setting of interface speed
D1- status diode




Figure 3. Diagram of connecting the transducer in the **wall** version .

3.4. Address configuration

The device is equipped with a DIP-SWITCH type switch (5, 6 or 7 position) for linking the address (from "1" to max. "127"). Setting the address "0" on the switch will use the address stored in the device via the MODBUS protocol ("1" by default).




Figure 4. Transducer addressing.

"0"-off
"1"- on

3.5. Speed configuration

The device is equipped with a system of 3 jumpers for hardware setting of the RS - 485 interface speed (according to the table below). No jumpers will use the speed value stored in device via the MODBUS protocol (default "9600 bps").




Figure 5. Configuration of the RS-485 interface speed.

3.6. Restoring factory settings

The function of restoring factory settings applies only to parameters of RS-485 interface transmission (including address and speed). To restore the settings, press and hold button S1 for about 2 seconds (protection against accidental operation). When the diode D1 blinks, release the button. The device will start working with new settings automatically.

4.

4.1. Guidelines

- In the case of work in the vicinity of large interferences, shielded cables should be used.
- The wire screen should be connected to the nearest PE point from the power supply side.

TRYB HALF DUPLEX

TERMINAL - urządzenie nadrzędne

R1, R2 - rezystory terminujące (wymagane)

R3, R4 - rezystory "pull up" i "pull down" (sugerowane)

(n) - maksymalna liczba urządzeń przyłączonych do magistrali




Figure 6. Connection of the transmitter to the RS-485 bus operating in HALF DUPLEX mode.

5. MODBUS protocol

5.1. Map of registers

Table of registers:

Registry number	The values	Description
1	1 - 1000	Relative humidity (1 = 0.1%, 1000 = 100%)
2	-4000 - 12380	Temperature [°C] (1 = 0.01 °C) with a sign
3	-4000 - 12380	Dew point [°C] (1 = 0.01 °C) with a sign
4	1234	Password register
5	1/2/3	Command register
6	according to the command table	Parameter register
7	0-65535	Counter of valid frames
8	0-65535	Exception counter
9	0-65535	Counter of incorrect CRC
10	0-65535	Counter of erroneous bytes
11	-	unused
12	0/1/2	Status register (0: "NO SENSOR", 1: "SENSOR OK", 2: "ERROR" (*))
13	1000 (0x03e8)	Test value - to verify the correctness of reading registers

(*) "NO SENSOR" - no sensor; "SENSOR OK" - proper sensor operation; "ERROR" - sensor error ;

Table of commands:

Command no	Function	parameters
1	Set the device address	1 - 247 (1-default value)
2	Set the speed transmission	96 - 9600 bps (default) 192 - 19200 b / s 384 - 38400 bps 576 - 57600 bps 1152 - 115200 b / s
3	Set the parity bits	0 - NO PARITY; no parity bit 1 - EVEN PARITY; (default value) 2 - ODD PARITY,
4	Set the bits stop	1 - 1 x STOP; 1 stop bit (default value) 2 - 2 x STOP; 2 stop bits
5	reset devices	1 - software reset of the device

Comments:

- Specifying an incorrect or out of range value of the parameter results in entering the value of 0xEEEE in the register of commands.
- Each time a command is called, it must be accompanied by entering the password (1234 decimal).
- Calling a command via individual entries to registrars must be completed by entering the password.

5.2. Protocol functions

The following functions of the MODBUS standard have been implemented in the transducer:

CODE	IMPORTANCE
03 (0x03)	Reading N x 16-bit registers
16 (0x10)	Write N x 16-bit registers

5.2.1. Reading the contents of the group of output registers (0x03)

The format of the request:

Description	Size	The values
Device address	1 byte	1 - 247 (0xF7)
Function code	1 byte	0x03
Address of the data block	2 bytes	0x0000 - 0xFFFF
Number of registers (N)	2 bytes	1 - 125 (0x7D)
CRC checksum	2 bytes	according to calculations

Response format:

Description	Size	The values
Device address	1 byte	1 - 247 (0xF7)
Function code	1 byte	0x03
Bytes counter	1 bytes	2 x N
Values of registers	N x 2 bytes	according to the map of registers
CRC checksum	2 bytes	according to calculations

Error format:

Description	Size	The values
Device address	1 byte	1 - 247 (0xF7)
Function code	1 byte	0x83
Error code	1 byte	0x01 / 0x02 / 0x03 / 0x04
CRC checksum	2 bytes	according to calculations

5.2.2. Writing to the group of output registers (0x10)

The format of the request:

Description	Size	The values
Device address	1 byte	1 - 247 (0xF7)
Function code	1 byte	0x10
Address of the data block	2 bytes	0x0000 - 0xFFFF
Number of registers (N)	2 bytes	1 - 123 (0x7B)
Bytes counter	1 byte	2 x N
The values	N x 2 bytes	user
CRC checksum	2 bytes	according to calculations

Response format:

Description	Size	The values
Device address	1 byte	1 - 247 (0xF7)
Function code	1 byte	0x10
Address of the data block	2 bytes	0x0000 - 0xFFFF
Number of registers (N)	2 bytes	1 - 123 (0x7B)
CRC checksum	2 bytes	according to calculations

Error format:

Description	Size	The values
Device address	1 byte	1 - 247 (0xF7)
Function code	1 byte	0x90
Error code	1 byte	0x01 / 0x02 / 0x03 / 0x04
CRC checksum	2 bytes	according to calculations

5.3. Data format




Figure 7. Data transfer in the MODBUS RTU standard implemented in the transducer.



Figure 8. Character format in the MODBUS RTU standard used in the transducer.




Figure 9. Format of data fields and CRC in the MODBUS RTU standard used in the transducer.

5.4. CRC checksum

According to the MODBUS standard, the polynomial was used to calculate the CRC checksum:
 $X^{16} + X^{15} + X^2 + 1$.

5.4.1. Bitwise CRC calculation algorithm:

Procedure for determining the CRC checksum using the bit method:

- loading the value 0xFFFF into the 16-bit CRC register;
- getting the first byte from the data block and performing the EX-OR operation from the younger byte of the CRC register, placing the result in the register;
- shifting the CRC register content to the right by one bit in the direction of least significant bit (LSB), resetting the most significant bit (MSB);

- d) the state of affairs device youngest bit (LSB) in the CRC register if its status is equal to 0, there is a return to point c, if 1, then the EX-OR operation of the CRC register with constant 0xA001;
- e) repeating c and d points up to eight times, which corresponds to processing and the entire byte;
- f) repeating the sequence b, c, d, e for the next byte of the message, continue this process until all bytes of the message are processed;
- g) the contents of the CRC register after the operations mentioned are the sought-after value of the CRC check sum ;
- h) adding a CRC checksum to the MODBUS RTU frame must be preceded by swapping the positions of the older and younger bytes of the CRC register.

5.4.2. Table-based CRC calculation algorithm:

An example of the implementation of the procedure for determining the CRC checksum using the array method :

```

/ * The function returns the CRC as a unsigned short type * /
unsigned short CRC16 (puchMsg, usDataLen)
/ * message to calculate CRC upon * /
unsigned char * puchMsg;
/ * quantity of bytes in message * /
unsigned short usDataLen;

{
    / * high byte of CRC initialized * /
    unsigned char uchCRCHi = 0xFF;
    / * low byte of CRC initialized * /
    unsigned char uchCRCLo = 0xFF;
    / * will index into CRC lookup table * /
    unsigned uIndex;

    / * pass through message buffer * /
    while (usDataLen--)
    {
        / * calculate the CRC * /
        uIndex = uchCRCLo ^ * puchMsg ++;
        uchCRCLo = uchCRCHi ^ auchCRCHi [uIndex];
        uchCRCHi = auchCRCLo [uIndex];
    }
    return (uchCRCHi << 8 | uchCRCLo);
}

/ * Table of CRC values for high-order byte * /
static unsigned char auchCRCHi [] = {
0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81,
0x40, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0,
0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01,
0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41,
0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81,
0x40, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0,
0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01,
0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40,
0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80,
0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1,
0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41,
0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81,
0x40
};

/ * Table of CRC values for low-order byte * /
static char auchCRCLo [] = {
0x00, 0xC0, 0xC1, 0x01, 0xC3, 0x03, 0x02, 0xC2, 0xC6, 0x06, 0x07, 0xC7, 0x05, 0xC5, 0xC4,
0x04, 0xCC, 0x0C, 0x0D, 0xCD, 0x0F, 0xCF, 0xCE, 0x0E, 0x0A, 0xCA, 0xCB, 0x0B, 0xC9, 0x09,
0x08, 0xC8, 0xD8, 0x18, 0x19, 0xD9, 0x1B, 0xDB, 0xDA, 0x1A, 0x1E, 0xDE, 0xDF, 0x1F, 0xDD,
0x1D, 0x1C, 0xDC, 0x14, 0xD4, 0xD5, 0x15, 0xD7, 0x17, 0x16, 0xD6, 0xD2, 0x12, 0x13, 0xD3,

```

```
0x11, 0xD1, 0xD0, 0x10, 0xF0, 0x30, 0x31, 0xF1, 0x33, 0xF3, 0xF2, 0x32, 0x36, 0xF6, 0xF7,  
0x37, 0xF5, 0x35, 0x34, 0xF4, 0x3C, 0xFC, 0xFD, 0x3D, 0xFF, 0x3F, 0x3E, 0xFE, 0xFA, 0x3A,  
0x3B, 0xFB, 0x39, 0xF9, 0xF8, 0x38, 0x28, 0xE8, 0xE9, 0x29, 0xEB, 0x2B, 0x2A, 0xEA, 0xEE,  
0x2E, 0x2F, 0xEF, 0x2D, 0xED, 0xEC, 0x2C, 0xE4, 0x24, 0x25, 0xE5, 0x27, 0xE7, 0xE6, 0x26,  
0x22, 0xE2, 0xE3, 0x23, 0xE1, 0x21, 0x20, 0xE0, 0xA0, 0x60, 0x61, 0xA1, 0x63, 0xA3, 0xA2,  
0x62, 0x66, 0xA6, 0xA7, 0x67, 0xA5, 0x65, 0x64, 0xA4, 0x6C, 0xAC, 0xAD, 0x6D, 0xAF, 0x6F,  
0x6E, 0xAE, 0xAA, 0x6A, 0x6B, 0xAB, 0x69, 0xA9, 0xA8, 0x68, 0x78, 0xB8, 0xB9, 0x79, 0xBB,  
0x7B, 0x7A, 0xBA, 0xBE, 0x7E, 0x7F, 0xBF, 0x7D, 0xBD, 0xBC, 0x7C, 0xB4, 0x74, 0x75, 0xB5,  
0x77, 0xB7, 0xB6, 0x76, 0x72, 0xB2, 0xB3, 0x73, 0xB1, 0x71, 0x70, 0xB0, 0x50, 0x90, 0x91,  
0x51, 0x93, 0x53, 0x52, 0x92, 0x96, 0x56, 0x57, 0x97, 0x55, 0x95, 0x94, 0x54, 0x9C, 0x5C,  
0x5D, 0x9D, 0x5F, 0x9F, 0x9E, 0x5E, 0x5A, 0x9A, 0x9B, 0x5B, 0x99, 0x59, 0x58, 0x98, 0x88,  
0x48, 0x49, 0x89, 0x4B, 0x8B, 0x8A, 0x4A, 0x4E, 0x8E, 0x8F, 0x4F, 0x8D, 0x4D, 0x4C, 0x8C,  
0x44, 0x84, 0x85, 0x45, 0x87, 0x47, 0x46, 0x86, 0x82, 0x42, 0x43, 0x83, 0x41, 0x81, 0x80,  
0x40  
};
```